

ADDENDA #1

Date: April 14, 2010

PROJECT:

Peace Lutheran Church
1000 Red River Avenue No.
Cold Spring, MN 56320

Make the following revisions to drawings and specifications previously issued.

GENERAL:

SPECIFICATIONS:

08800 - Glazing

This section is for “reference” and should be provided in the appropriate packages where glazing is required.

10651 – Operable Panel Partitions

STC rating of no less than 47 will be accepted, in lieu of STC 55 as indicated.

DRAWINGS

A8.1 Exterior doors 119A and 119B are to be “AL” type material, not “WD”.

Revised Hardware Groups (#7, 9, 10):


- Group #7 - Hinges
Exit Device
Threshold
Weatherstrip
Sweeps
Cylinder
Closer

- Group #9 - Hinges
Closer
Smoke Gasket
Exit Device/Lever
Vertical Rod
Magnetic Hold Open

- Group #10 - Hinges
Closer
Smoke Gasket
Exit Device
Magnetic Hold Open

APPROVALS

Section	Item	Manufacturer/Model
08411	Aluminum Framed Entrances	Tubelite T14000 Series
08620	Unit Skylights	Wasco Skylights
08800	Glazing	Vetrotech, Contraflam 90 with VDS 90 Framing
10651	Operable Panel Partitions	Kwik-Wall, 3000 Series

A handwritten signature in black ink, appearing to read "Lon Negen", written over a horizontal line.

Lon D. Negen, AIA, CID

Principal

Registration Number 41402

Date: April 14, 2010